

ADDENDUM #1

September 23, 2024
Wilson Fire Station Roof Replacement
50 Pine Lane, Windsor, CT 06095

The following changes, revisions, and/or additions are hereby made a part of the Contract Documents and shall supersede previously issued documents and shall become a part of the contract documents.

Information to Bidders:

1. Pre-bid meeting sign in sheet attached.
2. For Add Alternate # 3, Gutter size specification shall be 6K aluminum with matching 3" x 4" downspouts and hardware. This is in lieu of the 5K gutters originally specified.
3. Remove existing lead coated copper cut reglet and caulking between the Garage and Office area, replace in kind with new lead coated copper cut reglet counter-flashings. Seal reglet with new sealant. DO NOT seal or cover existing weep holes
4. Seal all masonry above the roof line between the Garage and Office area with two coats of approved masonry damp proofing.
5. Add the installation of new 6K gutter to Garage roof eve above the gable between the hips, pitch it to the back of the building, pipe it down to the shingled roof, add extension to the flat low slope roof (as shown on attached drawings).
6. Install closed valleys at all valley areas.
7. Remove abandoned exhaust duct in mechanical room (flat roof area as shown on attached drawings). Repair decking and sheetrock below decking to seal penetrations from said exhaust duct.
8. Delete, in its entirety, item 2, under "THE BIDS SHALL INCLUDE:". Item a "Contractor Prequalification Certificate" and item b "Update (Bid) Statement. The classification ROOFING is required as a minimum" is not required.

END OF ADDENDUM #1




**Wilson Fire Station
ROOF REPLACEMENT
WALKTHROUGH SIGN IN
September 18, 2024 - 8:30 AM.**

Name	Company Name & Address
YOUNG DEVELOPERS LLC	9 Hamolen Park Drive, Hamolen
Phone: 203-859-5320	Email: estimating@yolroofing.com
RSR Residential	8 Overlook Dr. MYSTIC
Phone: 860-214-4660	Email: tom@rsrresidential.com
Guaranteed Roofing	estimating@jrbbuildingllc.com
Phone: 860-546-6292	Email: 1 Knollwood Dr. Suite 25 Carterbury, CT
Eagle Rivet - John S.	Britton Dr. Bloomfield
Phone: 860-953-1231	Email: John.Schauss@EagleRivet.com
AVT Construction Etienne Ruiz	AVT construction 588 Hanover street, meriden, CT
Phone: 860-770-7103	Email:



Wilson Fire Station
ROOF REPLACEMENT
WALKTHROUGH SIGN IN
September 18, 2024 - 8:30 AM.

Name	Company Name & Address
Ryan Arnold	SilkTown Roofing
Phone: 860-647-0198	Email: Ryan@SilkTownRoofing.com
Oleg Volinuk	4 You LLC
Phone: 203-923-7876	Email: infoforyoullc@gmail.com
David Morneau	Atlantic Restoration
Phone: 860-426-1975	Email: davidm@AtlanticRestorationCT.com
Greg Rose	SR Products
Phone: 860-559-5175	Email: 6 Strong Ave Portland, CT
Russ Perkins	A1 Home Improvements LLC
Phone: 720-485-4112	Email: russ@a1roofproct.com



Install new gutter with down spout to flat roof (as shown yellow highlight). This is part of base bid.

Remove existing exhaust vent and repair decking and sheetrock to seal existing openings. Exhaust vent is no longer needed. This is part of base bid.